

| Туре                  | DID-E2  |
|-----------------------|---|
| Product               | Induction diffuser for bulkhead   |
| Manufacturer          | TROX GmbH Heinrich-Trox-Platz • 47504 Neukirchen-Vluyn • Germany Phone +49 (0) 2845 2020 • FAX +49 (0) 2845 202265 E-mail trox@trox.de • Internet www.troxtechnik.com |
| European standards    | EN 16798-3:2017-11  |
| German standards      | VDI 3803 Sheet 1:2010-02<br>VDI 6022 Sheet 1:2018-01  |
| Austrian standards    | ÖNORM H 6021:2016 08  |
| Swiss guidelines      | SWKI VA104-01   |
| Test location (plant) | TROX GmbH<br>Heinrich-Trox-Platz, 47504 Neukirchen-Vluyn, Germany   |

## Summary of the test result

For the purpose of this declaration of conformity a sample of each product type mentioned above was tested at the factory, and related data sheets, technical documentation and test reports were appraised.

The test of the above mentioned samples and the appraisal of the provided documents have shown that the hygiene requirements stipulated in the above mentioned standards and guidelines are met. This is to confirm that the products meet the hygiene requirements stipulated in the specified standards and guidelines.



Neukirchen-Vluyn, the 11.09.2018

Dr Sleich

Dipl.-Ing. Dirk Scherder VDI-geprüfter Fachingenieur RLQ (VDIcertified engineer for room air quality)

Dipl.-Ing. Jan Heymann Manager quality management